



NOTES:

1. METER BASE TO BE 200 AMP RATED MINIMUM.
2. THE INSTALLATION OF THE TRANSFER SWITCH SHALL NOT INTERFERE WITH TRAFFIC, DRIVEWAYS, OR SIDEWALKS NOR OBSTRUCT THE OPENING OF DOORS AND WINDOWS.
3. KITCHENER-WILMOT HYDRO STAFF TO REMOVE THE EXISTING METER. CUSTOMER/CONTRACTOR TO CONNECT THE TRANSFER SWITCH NEUTRAL TO METER BASE NEUTRAL WHILE THE KITCHENER-WILMOT HYDRO STAFF IS PRESENT. WITH PERMISSION OF KITCHENER-WILMOT HYDRO STAFF, CUSTOMER/CONTRACTOR TO PLUG IN THE TRANSFER SWITCH. KITCHENER-WILMOT HYDRO STAFF TO PLUG IN THE EXISTING METER.
4. ALL CUSTOMER OWNED EQUIPMENT AND INSTALLATION MUST BE APPROVED BY THE ELECTRICAL SAFETY AUTHORITY.
5. REFER TO ONTARIO ELECTRICAL SAFETY CODE FOR WIRING METHODS INCLUDING GROUNDING AND BONDING REQUIREMENTS.

Kitchener-Wilmot Hydro Inc. Certificate of Approval

The installation work covered by
K-W Hydro work
of this document meets the safety
requirements of Section 4 of Ontario
Regulation 22/04.

Name of P.Eng.: Shaun Wang
Signature: [Signature]
Date: June 5, 2018



REV No.	DESCRIPTION	DATE & INITIALS
INSTALLATION DETAILS CUSTOMER OWNED METER BASE PLUG-IN TRANSFER SWITCH 120/240V		
DRAWN	B. BIN	MAR. 1/18
DESIGNED	A. LEE	
CHECKED	<u>S.W.</u>	<u>Jun. 5, 2018</u>
APPROVED	<u>[Signature]</u>	<u>18-Jun-2018</u>
FILE No.		
		E 10700